



**PARTIAL FOUNDATION PLAN-PPOOL AREA**  
SCALE: 1/8"=1'-0"

**NOTES:**  
\* = VERIFY DIMENSION W/ARCH.  
SEE 2/S2.01 FOR STEP FOOTING DETAIL.  
SEE 1/S5.03 FOR REQ'D PRE-ENGINEERED BUILDING FRAME PROFILE AND DIMENSIONS.  
SEE 3/S2.01 FOR CRACK CONTROL JOINT DETAIL. LOCATION OF CONTROL JOINTS AND COLORED/STAINED CONCRETE TO BE COORDINATED WITH THE ARCHITECT. MAXIMUM SPACING OF CONTROL JOINTS TO BE 10'-0" O.C. EACH WAY & AT COLUMN LINES. CONSTRUCTION JOINT LAYOUTS TO BE SUBMITTED TO THE ENGINEER FOR FINAL APPROVAL.



FOOTING SCHEDULE			
f'c = 3000 psi FOR 2000 PSF SOIL BEARING			
FTG MARK	SIZE L x W x THK	REINFORCING (GRADE 60)	TOP FOOTING EL (LOU)
F4	4'-0"x4'-0"x1'-3"	5-#5 EA WAY	SEE PLAN
F5	5'-0"x5'-0"x1'-3"	6-#5 EA WAY	
F7	7'-0"x7'-0"x1'-3"	8-#6 EA WAY	
F8	8'-0"x8'-0"x1'-3"	9-#7 EA WAY	
F8A	8'-0"x8'-0"x1'-3"	9-#7 EA WAY TOP & BOTTOM	
F10	10'-0"x10'-0"x2'-3"	11-#8 EA WAY	
F6-12	6'-0"x12'-0"x1'-6"	7-#10 LONG; 14-#6 LAT	
F8-16	8'-0"x16'-0"x2'-3"	9-#7 LONGIT. TOP & BOT. 17-#7 TRANSV. TOP & BOT.	

THIS POOL TO BE AN  
**ALTERNATE**

**CONSTRUCTION DOCUMENTS**

**CARDINAL PARK NATATORIUM**

UNIVERSITY OF LOUISVILLE

Project: 03008  
Drawn: JLR  
Checked: MLL  
Scale: AS NOTED  
Issue Date: AUGUST 27, 2003  
Revision:

FOUNDATION PLAN  
MYRTHA POOL ALT.  
**S1.01A**