ALL WORK SHALL BE COMPLETED IN ACC CAMPUS CONSTRUCTION STANDARDS.

ALL WORK REQUIRING DOWNTIME OF ANY AREA IN THE BUILDING SHALL BE SCHEDULED 2 WEEKS IN ADVANCE, AND SHALL COMPLY WITH INTERIM LIFE SAFETY MEASURES. ALL PIPING IN ROOMS WITH CEILINGS SHALL BE ABOVE CEILING EXCEPT AS NOTED.

LOCATIONS OF PIPING AND EQUIPMENT ARE APPROXIMATE AND SUBJECT TO MINOR ADJUSTMENTS IN THE FIELD. DO NOT SCALE THE DRAWINGS. WHERE FIRE PROOFING IS SPRAYED ON EXISTING STRUCTURE ALL EXISTING CONDUITS, WATER, HYDRONIC, STEAM, CHILLED WATER, FIRE PROTECTION LINES, MED GAS, ETC. SHALL BE LOWERED TO BE BELOW FULL THICKNESS OF FIRE PROOFING WITH NO INTERFERENCE.

WHERE WORK IS REQUIRED ABOVE EXISTING LAY—IN, PLASTER OR GYPSUM BOARD CEILINGS, THE CONTRACTOR SHALL BE RESPONSIBLE FOR REMOVAL AND REINSTALLATION (OR REPLACEMENT, IF DAMAGED) OF ALL CEILING OR TILE AND GRID MEMBERS NECESSARY TO PERFORM HIS WORK. NEW TILE AND GRID SHALL MATCH THE SURROUNDING AREAS. ALL PATCHING WORK SHALL MATCH ADJACENT SURFACES.

SYMBOLS

<u>1 VALVE</u>)WL, SIPHON JET, 1½," TOP SPUD I MITH BOWL AT 15" AFF. PROVIDE N VALVE — ADA COMPLIANT SIPHON JET, 1½" TOP SPUD INLET, CHINA BOLT CAPS AND WHITE OPEN FRONT PLASTIC SEAT WITH SELF—SUSTAINING CHECK HINGES. MANUAL WITH RIM OF BOWL AT 17" AFF. FLUSH VALVE HANDLE SHALL BE A MAXIMUM OF 31" AFF. PROVIDE NEOPRENE GASKETS. ACCEPTABLE WATER ID AMERICAN STANDARD. FLUSH VALVES ARE ZURN, SLOAN AND MOEN. **PLUMBING** ×4° 74 ¾, * 34 %; '∕~

UNIVERSITY LOFTS - Renovate Academic Facility

ν,

UK School of Art & Visual Studies

ARCHITECTS

212 North Upper Street Lexington, Kentucky 40507-1001 p 859.252.6664 f 859.253.2358 www.omniarchitects.com

Job Number: 1205 NOT FOR CONSTRUCTION

1.5

Date: 03/2013

0.5

Drawn By: CE/CRK

0.5

2,

2,

0.5

2,

1.5

Checked By: JMS

4

Revision: XXX

Drawing or Design without the written

PLUMBING LEGEND