



- FIRE PROTECTION DEMO THIRD FLOOR PLAN TAGGED NOTES
- 1 EXISTING FIRE PROTECTION LINES AND SPRINKLER HEADS SHALL REMAIN.
 - 2 EXISTING CEILING MOUNTED SPRINKLER HEAD, TYPICAL.
 - 3 EXISTING SIDEWALL MOUNTED SPRINKLER HEAD, TYPICAL.
 - 4 PATCH AND REPAIR FIRE PROTECTION PIPING AS REQUIRED.
 - 5 EXISTING FIRE PROTECTION STAND PIPE TO REMAIN.
 - 6 ADJUST FIRE PROTECTION BRANCH LINES AND SPRINKLER HEADS AS NEEDED. FIELD VERIFY.
 - 7 CAP EXISTING FIRE PROTECTION PIPING.
 - 8 REMOVE EXISTING FIRE PROTECTION PIPING.
 - 9 REWORK FIRE PROTECTION PIPING SYSTEM IN ALTERNATE BID.

1 FIRE PROTECTION DEMO THIRD FLOOR PLAN
1/8" = 1'-0"

UNIVERSITY LOFTS - Renovate Academic Facility - UK School of Art & Visual Studies

FIRE PROTECTION DEMO THIRD FLOOR PLAN



212 North Upper Street
Lexington, Kentucky 40507-1101
www.omniarchitects.com

CONTRACT DOCUMENTS

FP1.3

Job Number: 1205 Date: 07/09/2013 Drawn By: CWE/CRK Checked By: JMS
Revision: A
This Drawing and the Design shown thereon are the property of Omni Architects. The user of this Drawing without the written consent of Omni Architects is prohibited.