


- TAGGED NOTES:**
- POTENTIAL GEOTHERMAL WELL FIELD. 60 WELLS, 20 FT ON CENTER, 300 FEET DEEP.
  - GEOTHERMAL VAULT.
  - TRAFFIC RATED GEOTHERMAL VAULT.
  - DEMOLISH EXISTING CHILLER, PAD AND FENCE ENCLOSURE. CAP PIPING BELOW GRADE.
  - REFER TO BASEMENT MECHANICAL DEMOLITION PLAN FOR CONTINUATION.
  - REFER TO MECHANICAL NEW WORK BASEMENT PLAN FOR CONTINUATION.
  - EXISTING TRANSFORMERS TO REMAIN.
  - EXISTING WATER VAULT TO REMAIN.
  - EXISTING TELEPHONE CONDUIT.
  - EXISTING COMMUNICATIONS CONDUIT TO REMAIN. REMOVE EXISTING CABLE AND REPLACE AS SHOWN ON COMMUNICATION RISER.
  - EXISTING ELECTRICAL SERVICE CONDUIT TO REMAIN.
  - EXISTING SPRAGUE GENERATOR, PROVIDE NEW FEEDER TO CSG BUILDING PER ONE-LINE.
  - REMOVE FEEDER FOR CHILLER. REUSE CONDUIT FOR GENERATOR CIRCUIT.
  - ALL TRENCHES, PIPING, AND WELLS SHALL BE KEPT OUT OF THE DRIP LINE OF ANY TREES. WELLFIELD APPROXIMATELY 225 FT BY 125 FT.
  - REFER TO PLUMBING NEW WORK BASEMENT FLOOR PLAN FOR CONTINUATION OF WATER LINES.
  - PROVIDE 3'X3'X3' PRECAST HANDHOLE.

REVISIONS	DATE	COUNCIL OF STATE GOVERNMENTS - HEADQUARTERS BUILDING	
1		2760 RESEARCH PARK DRIVE LEXINGTON, KY 40511	
2			
3			
4			
5			
6			
7			
8			
9			
RECORD DATE		SITE UTILITIES PLAN	
JULY 2013		DRAWING NO	
DRAWN BY		COMMONWEALTH OF KENTUCKY	
MCW		FINANCE AND ADMINISTRATION CABINET	
CHECKED BY		DIVISION OF ENGINEERING	
CMR		DEPARTMENT FOR FACILITIES MANAGEMENT	
A & E FILE NO		FRANKFORT, KENTUCKY	
1302.00		REVIEWED	
CSG13		DNY, OF ENGR.	
JULY 2013		ENGR. FILE NO	
		785-CBRR-8C01-00	
AGENCY		DATE	
AUTHORIZED AGENT		APPROVED FOR PROGRAM CONCEPT ONLY	
DIVISION OF ENGINEERING		DATE	
		APPROVED FOR PROGRAM CONCEPT ONLY	



212 North Upper Street  
Lexington, Kentucky 40507-0001  
P 606.252.6664 F 606.252.2398  
www.omniarchitects.com