



# LONGITUDINAL SECTION AT ATRIUM LOOKING NORTH

1/8" = 1'-0"

**RECORD DOCUMENTS**  
These Record Documents have been prepared based on information provided by others. The Consultant has not verified the accuracy and/or completeness of this information and shall not be responsible for any errors or omissions that may be incorporated as a result of erroneous information provided by others.

**Omni** ARCHITECTS  
12/1/02  
DATE

**LONGITUDINAL SECTION AT ATRIUM  
LOOKING NORTH**

# A-3.1

- |  |  |
|--|--|
| <p>1 STRUCTURAL CONCRETE FOUNDATION - SEE STRUCTURAL DRAWINGS FOR DIMENSIONS, BEARING POINTS AND REINFORCING</p> <p>2 STRUCTURAL CONCRETE SLAB - SEE STRUCTURAL DRAWINGS FOR DIMENSIONS, REINFORCING, AND ENGINEERED FILL</p> <p>3 EXPOSED CAST-IN-PLACE CONCRETE SURFACE - DO NOT PAINT</p> <p>4 EXPOSED CAST-IN-PLACE CONCRETE WEARING SLAB OVER RIGID INSULATION OVER MEMBRANE FLASHING OVER STRUCTURAL CONCRETE SLAB</p> <p>5 LIGHTWEIGHT CONCRETE TOPPING OVER STRUCTURAL CONCRETE SLAB - SLOPE AT 1/4" PER FOOT TO DRAIN AS SHOWN ON ROOF PLAN</p> <p>6 EXPOSED CAST-IN-PLACE CONCRETE WITH ARCHITECTURAL FINISH AND RUSTICATION JOINTS</p> <p>7 CONCRETE MASONRY UNITS WITH HORIZONTAL JOINT REINFORCING AT 16" ON CENTER VERTICALLY - SEE FINISH SCHEDULE FOR FINISH</p> <p>8 EXPOSED STEEL STRUCTURE WITH INTUMESCENT PAINTED FINISH - SEE STRUCTURAL DRAWINGS FOR SIZE AND DIMENSIONS</p> <p>9 STEEL STRUCTURE WITH TAPED JOINTS OVER 1/2" GLASSMATT-FACED EXTERIOR GYPSUM SHEATHING ON EXTERIOR FACE OF WALL AND FIRE VAPOR BARRIER ON INTERIOR FACE OF WALL - FULL WALL CAVITY WITH BATT INSULATION</p> <p>10 METAL ROOF DECK - SEE STRUCTURAL DRAWINGS FOR DEPTH AND GAUGE</p> <p>11 STEEL EDGE ANGLE - SEE STRUCTURAL DRAWINGS FOR SIZE AND DIMENSIONS</p> <p>12 15 GAUGE COLD-FORMED METAL STUDS AT 16" ON CENTER</p> <p>13 16 GAUGE COLD-FORMED METAL FRAMING AT 16" ON CENTER</p> <p>14 SECURE EACH COLD-FORMED FRAMING MEMBER TO STEEL STRUCTURE WITH SLIP JOINT FOR DEFLECTION</p> <p>15 APPROXIMATE FINISH GRADE - SEE SITE DRAWINGS FOR ELEVATION</p> <p>16 PROVIDE DOUBLE STUDS AT THIS LOCATION, TYPICAL</p> <p>17 METAL STUDS AT 16" ON CENTER</p> <p>18 METAL FRAMING AT 16" ON CENTER</p> <p>19 EXTERIOR ALUMINUM GUARDRAIL WITH BLACK FLUOROPOLYMER FINISH - 42" HIGH</p> <p>20 METAL HANDRAIL / GUARDRAIL WITH PAINTED FINISH</p> <p>21 HOLLOW METAL DOOR AND FRAME WITH PAINTED FINISH</p> <p>22 FIRE-TREATED WOOD BLOCKING</p> <p>23 SHIM AS REQUIRED AT PERIMETER</p> <p>24 SOLID SURFACING WINDOW SILL</p> <p>25 APPROXIMATE FINISH GRADE - SEE SITE DRAWINGS FOR ELEVATION</p> <p>26 AIR INFILTRATION BARRIER WITH TAPED JOINTS OVER 1/2" GLASSMATT-FACED EXTERIOR GYPSUM SHEATHING ON EXTERIOR FACE OF WALL AND FIRE VAPOR BARRIER ON INTERIOR FACE OF WALL - FULL WALL CAVITY WITH BATT INSULATION</p> <p>27 BACKER ROD AND SEALANT IN COMPOSITE ALUMINUM PANEL JOINTS IN THIS LOCATION ONLY</p> <p>28 COMPOSITE ALUMINUM SPANDREL PANEL WITH FINISH TO MATCH SURROUNDING FRAME</p> <p>29 COMPOSITE ALUMINUM PANEL SYSTEM WITH FLUOROPOLYMER FINISH (COLOR SELECTED BY ARCHITECT) WITH CONCEALED FASTENERS, ALUMINUM MOUNTING TRACKS, AND SHIMS AS REQUIRED - EACH PANEL TO HAVE FLASHING AND WEAP HOLES - DO NOT CALK OR GASKET JOINTS BETWEEN PANELS</p> <p>30 COMPOSITE ALUMINUM PANEL SYSTEM BEYOND</p> <p>31 COMPOSITE ALUMINUM PANEL COPING WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>32 12" GLASSMATT-FACED GYPSUM THERMAL BARRIER BOARD</p> <p>33 EXTRUDED ALUMINUM COPING WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>34 EXTRUDED ALUMINUM FASCIA/ROOF EDS WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>35 HOT-ASPHALT/APPLIED MULTI-PLY SBS MODIFIED BITUMEN ROOFING SYSTEM OVER POLYISOCYANURATE INSULATION BOARD - INSULATION TO BE APPROVED BY ROOFING MANUFACTURER - PROVIDE PROTECTION BOARD WHERE REQUIRED BY ROOFING MANUFACTURER</p> <p>36 SLOPE RIGID INSULATION BOARD AT 1/4" PER FOOT TO DRAIN AS SHOWN ON ROOF PLAN - R-20 AVERAGE</p> <p>37 UNIFORM THICKNESS RIGID INSULATION BOARD - R-20 MINIMUM</p> <p>38 12" GLASSMATT-FACED GYPSUM THERMAL BARRIER BOARD</p> <p>39 THERMALLY-BROKEN ALUMINUM STOREFRONT FRAMING SYSTEM WITH BLACK FLUOROPOLYMER FINISH</p> <p>40 TRANSLUCENT COMPOSITE FIBERGLASS PANELS WITH ALUMINUM FRAME WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>41 THERMALLY-BROKEN ALUMINUM STOREFRONT FRAMING SYSTEM WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>42 THERMALLY-BROKEN ALUMINUM CURTAINWALL FRAMING SYSTEM WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>43 THERMALLY-BROKEN ALUMINUM SKYLIGHT WITH FLUOROPOLYMER FINISH</p> <p>44 1" INSULATING CLEAR GLAZING WITH LOW-EMISSIVITY COATING</p> <p>45 11" INSULATING GREY TINTED GLAZING WITH LOW-EMISSIVITY COATING</p> <p>46 5/8" GYPSUM BOARD OVER VAPOR BARRIER OVER RIGID INSULATION OVER 2" METAL FURRING</p> <p>47 5/8" GYPSUM BOARD - SEE FINISH SCHEDULE FOR FINISHES AND WALL TYPE SCHEDULE FOR RATED MATERIALS</p> <p>48 5/8" GYPSUM BOARD BEYOND</p> <p>49 SUSPENDED ACOUSTIC CEILING SYSTEM WITH 2"x2" PANELS - SEE FINISH SCHEDULE FOR TYPE</p> <p>50 3 1/2" TAPERED RESILIENT BASE - SEE SCHEDULE FOR TYPE</p> <p>51 WALL BASE - SEE SCHEDULE FOR TYPE</p> <p>52 STEEL ACOUSTIC LOUVER WITH FLUOROPOLYMER FINISH TO MATCH ALUMINUM COMPOSITE PANEL COLOR</p> <p>53 LABORATORY CASEWORK - SEE ENLARGED PLANS AND ELEVATIONS FOR CONFIGURATION AND DIMENSIONS</p> <p>54 LIGHTWEIGHT CONCRETE TOPPING OVER STRUCTURAL METAL DECK - SLOPE AT 1/4" PER FOOT TO DRAIN AS SHOWN ON ROOF PLAN</p> <p>55 EXPOSED CONCRETE FLOOR SLAB WITH TROWEL FINISH AND CLEAR HARDENER / SEALER</p> <p>56 8" HIGH SURFACE-MOUNTED CAST ALUMINUM LETTERS / NUMBERS</p> <p>57 COMPOSITE DRAINAGE / PROTECTION BOARD WITH INTEGRAL FILTER FABRIC OVER RUBBERIZED ASPHALT WATERPROOFING MEMBRANE - PROVIDE FOUNDATION DRAINS AS SHOWN</p> <p>58 1" DEEP REVEAL IN CONCRETE SURFACE</p> <p>59 5/8" GYPSUM BOARD OVER METAL FRAMING AT 16" ON CENTER</p> <p>60 STRUCTURAL CONCRETE FRAME AND SLAB - SEE STRUCTURAL DRAWINGS FOR DIMENSIONS AND REINFORCING</p> <p>61 EXPOSED STEEL STAIR SYSTEM WITH PAINTED FINISH - FILL STEEL TREAD PANS WITH CONCRETE AND PROVIDE 1 1/2" DIAMETER PIPE HANDRAILS AND GUARDRAILS AT 47" ABOVE FLOOR</p> <p>62 FLOOR FINISH - SEE ROOM FINISH SCHEDULE FOR TYPE</p> | <p>63 66" DOUBLE-WALLED STAINLESS STEEL EXHAUST STACK</p> <p>64 EXPOSED GALVANIZED STEEL TUBE FRAME WITH PAINTED FINISH</p> <p>65 ATRIUM EXHAUST FAN</p> <p>66 66" DOUBLE-WALLED STAINLESS STEEL EXHAUST STACK</p> |
|--|--|

REVISIONS	DATE
1	
2	
3	
4	
5	
6	
7	
8	
9	

**NORTHERN KENTUCKY UNIVERSITY  
NATURAL SCIENCE BUILDING**

RECORD DATE: \_\_\_\_\_

DRAWN BY: **EZ, MB**

CHECKED BY: **MWJ**

A & E FILE # \_\_\_\_\_

DATE: **6/99**

AGENCY AUTHORIZED AGENT: \_\_\_\_\_

DIVISION OF ENGINEERING: \_\_\_\_\_

APPROVED FOR PROGRAM CONCEPT ONLY

DATE: \_\_\_\_\_

DRAWING # **A-3.1**

REVIEWED DIV. OF ENGR. **I-111**

ENGR. FILE # **I-111**

**Omni** Architects